



中国认可
国际互认
校准
CALIBRATION
CNAS L0544

湖北省计量测试技术研究院

Hubei Institute of Measurement and Testing Technology

校准证书

Calibration Certificate

证书编号: 2026DW044000067
Certificate No.

委托方
Client

中油(新疆)石油工程有限公司

委托方地址
Address

新疆克拉玛依市克拉玛依区塔河路3号

器具名称
Name of instrument

变频串联谐振耐压试验装置

制造厂商
Manufacturer

武汉特高压电力科技有限公司

型号/规格
Type/Specification

UHV-88kVA/44kV

器具编号
Serial No.

2603042

湖北省计量测试
证书骑缝



批准人
Approved by

李亮波

核验员
Checked by

吴军

校准员
Calibrated by

董新宇

样品接收日期

Date of Application

2026 年 02 月 28 日

Year

Month

Day

校准日期

Date of Calibration

2026 年 02 月 28 日

Year

Month

Day

签发日期

Date of Issue

2026 年 03 月 09 日

Year

Month

Day



地址: 湖北省武汉市东湖新技术开发区茅店山中路二号(总部)

Add: No.2, Maodianshanzhong Road, East Lake High-tech Development Zone, Wuhan, Hubei

网址(Web site): <http://www.himtt.net>

邮编(Post Code): 430223

电话(Tel): 027-81925136

传真(Fax): 027-81925137

第 1 页共 3 页

Page of total pages

Z260200474

Z260200474-1-001



扫描全能王 创建

● 本院是政府计量行政管理部门依法设立的国家法定计量检定机构

This laboratory is a legal metrological verification institution established by the government metrological administrative department according to law.

● 本次校准的技术依据 (代号、名称)

Reference documents for the Calibration (Code, Name)

参照 JJF (浙) 1144-2018《交流高压试验装置校准规范》

● 本次校准所使用的主要计量标准器具

Main standards of measurement used in the Calibration

名称 Name	型号/编号 Type/Serial No.	测量范围 Measuring Range	不确定度/准确度等级/ 最大允许误差 Uncertainty/Accuracy Class/ Maximum Permissible Error	证书编号/ 溯源机构 Certificate No / Traceability Agency	有效期限 Due date
分体式变频分 压器标准装置	BZNFY-500p F/300kV 2110001D	电压: 150kV, 300kV; 频 率: (30~300) Hz	MPE: $\pm 0.85\%$	(计)字 第202501 4269号 国家高电压计量 站	2026-10-30

● 校准地点及环境条件

Environmental condition and Place for the Calibration

地 点: 委托方高压车间

Site

温 度: 20.0 °C

Temperature

相对湿度: 36 %

R.H.

其 它: ----

Others

气 压: ---- kPa

Pressure

原始记录编号: 2026DW044000067

Record No.

● 备注 ----

Note

- 1、本院所出具的量值 (校准结果), 均可溯源至国家计量基准和 (或) 国际单位制 (SI)。

All data issued by this laboratory are traceable to national primary standards and international system of units (SI).

- 2、校准结果, 仅对受校样品的本次校准有效。校准证书封面未加盖校准专用章无效。

It's Effect That Results of This Report Relate Only To The Sample(s) Calibrated. It's Invalid That The Certificate Cannot Be Stamped.

- 3、未经本院书面批准, 不得复制 (全文复制除外)。

Without the written approval of the court, it is not allowed to copy (except full-text copy)

- 4、“委托方”、“委托方联络信息”由委托方提供, “制造厂”、“型号规格”、“器具编号”为仪器上标注。

The information Client and Contact Information are provided by client, and the Manufacturer, Type /Specification, Serial No. are marked on the items.

校准证书专用续页

Continued page of calibration certificate

第 2 页共 3 页

Page of total pages



扫描全能王 创建

校准结果
Results of Calibration

交流高压测量:		
被测显示值(kV)	实测标准值(kV)	测量不确定度 U_{rel} , $k=2$
9.76	9.63	1.0%
20.37	20.22	1.0%
31.50	31.24	1.0%
39.37	39.03	1.0%
43.99	43.73	1.0%

以下空白

